



BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International (BI). BTL is a registered trademark of BI.

## BACnet Testing Labs Product Listing

*This product has been tested at the BACnet Testing Labs and found to comply with all the necessary interoperability requirements in place on the published test date. This listing represents the tested capability of the Listed Product. For information on additional functionality that was not covered in the test process, refer to the Manufacturer's PICS statement on the BI website.*

### Listing Information

Vendor		Listing Status
Delta Controls 17850 – 56 <sup>th</sup> Ave. Surrey, BC Canada V3S-1C7		Listed Product
Test Requirements	BACnet Protocol Revision	Date Tested
Requirements as of <b>May 2005</b>	Revision 4 (135-2004)	September 2006

Product Name	Model Number	Software Version
Network Thermostat/Controller (Digital) BACstat II R4 DNT-T103	DNT-T103	Release 4
Network Thermostat/Controller with Humidity (Digital) BACstat II R4 DNT-H103B	DNT-H103B	Release 4
Network Thermostat/Controller (Analog) BACstat II R4 DNT-T221	DNT-T221	Release 4
Network Thermostat/Controller with Humidity (Analog) BACstat II R4 DNT-H121B	DNT-H121B	Release 4
Network Thermostat BACstat II R4 DNS-24	DNS-24	Release 4
Network Thermostat with Humidity BACstat II R4 DNS-H24B	DNS-H24B	Release 4

## Device Profiles

Profile	Model Numbers
BACnet Application Specific Controller (B-ASC)	All Devices.

## BIBBs Supported

Data Sharing	ReadProperty-B	DS-RP-B
	ReadPropertyMultiple-B	DS-RPM-B
	WriteProperty-B	DS-WP-B
	COV-B	DS-COV-B

Device and Network Management	Dynamic Device Binding-B	DM-DDB-B
	Dynamic Object Binding-B	DM-DOB-B
	DeviceCommunicationControl-B	DM-DCC-B
	TimeSynchronization-B	DM-TS-B
	ReinitializeDevice-B	DM-RD-B

## Object Type Support

Analog Input	Analog Value	Device
--------------	--------------	--------

## Data Link Layer Options

Media	Options
MS/TP master	9600, 19200, 38400, 76800

## Character Set Support

ANSI X3.4
-----------